

Technical Compliance Statement



中国认可
国际互认
检测
TESTING
CNA S L8469

Ref. No.: ACWE- RC210381 (ACWE-C1W2111102)

For the following equipment

Applicant : GoodWe Technologies Co.,Ltd.
Manufacturer : GoodWe Technologies Co.,Ltd.
Product : Grid-Tied PV Inverter
Model Number : (1)GW8000-SDT-20 (2)GW10K-SDT-20
Brand : GOODWE

We, **AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.** hereby certify that the above product has been tested by us with the listed standards and found in compliance with the council EMC directive 2014/30/EU. The test data & results are issued on the EMC test report No. **ACWE-E2109001A**.

Emission: EN 61000-2-2:2002+A2:2019

**EN IEC 61000-6-3:2021, EN 61000-6-3:2007+A1:2011+AC:2012,
EN IEC 61000-6-4:2019, EN 61000-6-4:2007+A1:2011
(IEC 61000-6-3:2011, IEC 61000-6-4:2006+A1:2010)
and AS/NZS 61000.6.3:2012; AS/NZS 61000.6.4:2012
EN 61000-3-2:2019+A1:2021, EN 61000-3-2:2014,
EN 61000-3-3:2013+A1:2019, EN 61000-3-3:2013
(IEC 61000-3-2:2018, IEC 61000-3-3:2013+A1:2017)**

Immunity: EN IEC 61000-6-1:2019, EN 61000-6-1:2007,

**EN IEC 61000-6-2:2019, EN 61000-6-2:2005+AC:2005
(IEC 61000-6-1:2016, IEC 61000-6-2:2016)
(IEC 61000-4-2:2008, IEC 61000-4-3:2006+A2:2010,
IEC 61000-4-4:2012, IEC 61000-4-5:2014,
IEC 61000-4-6:2013, IEC 61000-4-8:2009, IEC 61000-4-11:2004+A1:2017)**

Dec.07, 2021

Ken Lu/ Vice General Manager

AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.

The statement is based on a single evaluation of one sample of the above-mentioned product. It does not imply an assessment of the whole production and does not permit the use of the test lab logo.

Technical Compliance Statement



中国认可
国际互认
检测
TESTING
CNA S L8469

Ref. No.: ACWE-RC210380 (ACWE-C1W2111101)

For the following equipment

Applicant : GoodWe Technologies Co.,Ltd.
Manufacturer : GoodWe Technologies Co.,Ltd.
Product : Grid-Tied PV Inverter
Model Number : (1)GW12K-SDT-20 (2)GW15K-SDT-20
(3)GW17K-SDT-20 (4)GW20K-SDT-20
(5)GW12KLV-SDT-20
Brand : GOODWE

We, **AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.** hereby certify that the above product has been tested by us with the listed standards. The test data & results are issued on the EMC test report No. **ACWE-E2109002A.**

Emission: EN 61000-2-2:2002+A2:2019

EN IEC 61000-6-3:2021, EN 61000-6-3:2007+A1:2011+AC:2012,
EN IEC 61000-6-4:2019, EN 61000-6-4:2007+A1:2011
(IEC 61000-6-3: 2011, IEC 61000-6-4:2006+A1:2010)
and AS/NZS 61000.6.3: 2012; AS/NZS 61000.6.4: 2012
EN IEC 61000-3-11:2019, EN 61000-3-11:2019,
EN 61000-3-12:2011+AC:2013, EN 61000-3-12:2011+AC:2013

Immunity: EN IEC 61000-6-1:2019, EN 61000-6-1:2007,

EN IEC 61000-6-2:2019, EN 61000-6-2:2005+AC:2005
(IEC 61000-6-1:2016, IEC 61000-6-2:2016)
(IEC 61000-4-2:2008, IEC 61000-4-3:2006+A2:2010,
IEC 61000-4-4:2012, IEC 61000-4-5:2014,
IEC 61000-4-6:2013, IEC 61000-4-8:2009, IEC 61000-4-34:2005)

Dec.07, 2021

Ken Lu/ Vice General Manager

AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.



Deutsche
Akkreditierungsstelle
D-PL-18968-01-00

The statement is based on a single evaluation of one sample of the above-mentioned product. It does not imply an assessment of the whole production and does not permit the use of the test lab logo.